

DELHI JAL BOARD
GOVT. OF NCT OF DELHI
RWS QUALITY CONTROL DIVISION
(South / South-West) GK - I

Bottling Plant, Greater Kailash-I, New Delhi-110048

No.: 112

CHEMICAL ANALYSIS REPORT
AS PER IS - 10500(2012)

Analysis Report of Water Sample Collected from: Vide challan No- 386, Dated:- 21.02.18,
M/s Poorna Prayna Public School, Sector- D, Pocket.-III, Vasant Kunj N.D-70,
D Tap Nr Water Tank, Ground floor (Direct DJB supply) in Premises of above School.

Ref. : ACWA (RWS)

Date 03.03.18

S.No.	PARTICULARS	Units	Result	Remarks
	PHYSICAL EXAMINATION		(1)	
1.	Date of Collection/Report		26-02-18	
2.	Colour/Clarity (5-15)	Hazen	Clear	
	Odour		No Obj	
4.	Turbidity (1-5)	NTU	0.92	
5.	Ph-Value (6.5-8.5)	-	7.7	
6.	Electrical Conductivity	umh0/cm2	225	
7.	Total Diss. Solid (500-2000)	mg/l	110	
	CHEMICAL EXAMINATION			
1.	Phenophthalin Alkalinity (CaCO3)	mg/l	NIL	
2.	Total Alkalinity (200-600)	"	68	
3.	Total Hardness (200-600)	"	90	
4.	Carbonate Hardness	"	68	
5.	Non Carbonate Hardness	"	22	
6.	Calcium Hardness	"	54	
7.	Magnesium Hardness	"	36	
8.	Calcium as Ca (75-200)	"	21.6	
9.	Magnesium as mg (30-100)	"	8.64	
10.	Ammonia (Free & Saline) (N) (0.5)	"	NIL	
11.	Nitrite (N)	"	NIL	
12.	Nitrate (No3) (45)	"	2.0	
13.	Sulphate (So4) (200-400)	"	21.5	
14.	Chloride (cl) (250-1000)	"	14	
15.	Iron (Fe) (0.3)	"	0.06	
16.	Fluoride (F) (1-1.5)	"	0.45	
17.	Chromium Cr6+(0.05)	"	-	
18.	Cyanide (CN) (0.05)	"	-	
19.	Aluminium (0.03-0.2)	"	-	
20.	Residual Chlorine (0.2-1.0)	"	1.0	
21.				

On the basis of tested Parameters, the above water sample conform to the drinking water Specification IS 10500-2012 hence fit for drinking Purpose.

B.S.

ASSTT. CHEMIST

B
03/03/18
CHEMIST

[Signature]
03/03/18
ACWA (RWS)S

Copy to : 1. Chief Water Analyst for information Please.
2. Office Copy for Record

DELHI JAL BOARD

GOVT. OF NCT DELHI
RURAL WATER SUPPLY LABORATORY
SOUTH, GK-I, NEW DELHI-48

Bacteriological Analysis Report

Ref.: DJB/DTQC/ACWA, RWS (SOUTH) P.S. (Bact.)/ P1-P4/26/02/2018

To

Poorna Prajna Public Party's ref. & Date PPPS/2017-18/21/02/2018

Sector-D Pocket-III Dept. Challan No. & Date 386 Dt- 21/02/2018

Valant kunj. Date of sample collection 26/02/2018

New Delhi-110070 No. of sample (s) Four

Note : Coliform count at 37° C/100 ml after 48 Hrs. Reported on dt- 28/02/2018

S. No. as in record	Particulars	Clarity	Residual Chlorine Mg/L	MPN 100 ML
P1	Tap (Direct DJB Supply) Near water tank ground floor in school premises.	Clear	1.0	0
P2	Tap 1st floor Near stairs in school premises	Clear	0.5	0
P3	Tap 2nd floor Near stairs in school premises	Clear	0.5	0
P4	Tap (After R.O) 3rd floor in school premises	Clear	NIL	0

Remarks The aforesaid Collected Water samples were found Bacteriological Satisfactory.

Asstt. Bacteriologist
05/03/2018

Bacteriologist

ACWA
RWS (South)
5/03/18



SOUTH DELHI MUNICIPAL CORPORATION
PUBLIC HEALTH DEPARTMENT : SOUTH ZONE
GREEN PARK, AUROBINDO MARG NEW DELHI 110016

No: DHO/SZ/2022/D-1259

Dated 28/7/2022

SCHOOL HEALTH CERTIFICATE

1. Name of the School..... Poorna Prajna Public School
2. School Address..... Sec-D, Pkt-III, Vasant Kunj, New Delhi-110070
3. No. of Shift..... One Timing..... Morning
4. No. of Students: Boys..... Girls..... Total.....
5. No. of Staffs: Male..... 24 Female..... 88 Total..... 112

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient..... Sufficient
2. The Classrooms are Well Lighted/ ill lighted..... well lighted
3. The Classrooms are Well Ventilated/ ill ventilated..... well ventilated
4. The Classrooms are kept / Not kept Neat & Clean: Neat & clean
5. The Classrooms/Building requires/ do not required Whitewash etc. Do not required
6. The Drinking Water is Wholesome/ not wholesome wholesome
7. The Latrine arrangement is Sanitary/ insanitary..... Sanitary

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is ... sufficient
2. One latrine for 40 male student is required so total is ... sufficient
3. Separate Toilet arrangement for staff present: Yes/No..... Yes
4. The Overall facilities: Good/ Adequate/Inadequate ... Good from health point of view and valid upto one year from issuance date.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

Dr. Dhanak Mittal
28/7/2022
Deputy Health Officer
South Zone
Dy. Health Officer/SZ

Heet
28/7/22